

Гпод.: 0.03_ - 30.0_м3/ч ДУ= ___мм
 Гобр.: 0.03_ - 30.0_м3/ч ДУ= ___мм
 Гп : 10___л/имп

Посуточная ведомость учета параметров теплопотребления
 с _18.03.2023_ по _18.04.2023_

Дата	Работы	Классиф	М1	М2	В1	В2	Вн	М1-М2	М2-М1	Утечка	подмес	атм	атм	Тн	Тр	Температура, °С	Давление	Время, час		
ошибок	Гкал															t1	t2	t1-t2	p1	p2
18.03.23	2.019		126.1021	101.6953	128.4600	103.2871	0.00	24.4067	-	63.96	57.45	6.51	9.0	0.4	0.00	24.00				
19.03.23	2.242		129.1484	99.8862	131.5327	101.4375	0.00	29.2622	-	63.50	57.18	6.32	9.0	0.4	0.01					
20.03.23	1.827		106.7383	82.8018	108.7485	84.1138	0.00	23.9365	-	64.20	57.81	6.40	9.2	0.4	0.23					
21.03.23	2.358		121.8105	89.0605	124.0625	90.4595	0.00	32.7500	-	63.67	57.50	6.17	11.7	0.4	0.22					
22.03.23	1.716		108.6997	89.1392	110.7690	90.5337	0.00	19.5605	-	64.37	57.39	6.98	7.4	0.4	0.00	24.00				
23.03.23	1.657		119.9009	101.9048	122.1255	103.5088	0.00	17.9961	-	63.90	57.58	6.32	12.7	0.4	0.00	24.00				
24.03.23	1.708		121.9771	103.2134	124.2515	104.8481	0.00	18.7637	-	64.07	57.79	6.28	13.1	0.4	0.00	24.00				
25.03.23	1.645		120.9849	103.4819	123.2500	105.1333	0.00	17.5029	-	64.26	57.99	6.27	14.0	0.4	0.00	24.00				
26.03.23	1.833		124.8428	102.9976	127.2100	104.6294	0.00	21.8452	-	63.88	57.75	6.13	3.9	0.4	0.00	24.00				
27.03.23	1.670		110.5215	91.5044	112.6563	92.9341	0.00	19.0171	-	64.19	57.36	6.83	0.5	0.4	0.00	24.00				

128.03.23	1.686	103.7529	105.7559	84.3145	85.6138	0.00	19.4385	-	64.27	56.97	7.31	0.8	0.4	0.00	24.00
129.03.23	1.758	105.0791	107.0723	83.8911	85.1753	0.00	21.1880	-	63.82	56.74	7.09	3.8	0.4	0.00	24.00
130.03.23	1.706	103.9248	105.9287	84.1699	85.4736	0.00	19.7549	-	64.37	57.09	7.28	2.4	0.4	0.00	24.00
131.03.23	1.634	102.6113	104.6299	84.5327	85.8506	0.00	18.0786	-	64.79	57.35	7.44	0.7	0.4	0.00	24.00
101.04.23	1.688	103.8340	105.8467	84.2295	85.5298	0.00	19.6045	-	64.27	57.02	7.25	0.1	0.4	0.00	24.00
102.04.23	1.786	106.0371	108.0684	84.1475	85.4399	0.00	21.8896	-	63.87	56.84	7.03	-0.0	0.4	0.00	24.00
103.04.23	1.654	112.7129	114.9258	94.2124	95.7202	0.00	18.5005	-	64.75	58.10	6.65	0.5	0.4	0.00	24.00
104.04.23	1.678	121.9824	124.3301	102.6333	104.2773	0.00	19.3491	-	64.11	58.12	5.99	0.9	0.4	0.00	24.00
105.04.23	1.697	122.5410	124.8350	102.8467	104.4707	0.00	19.6943	-	63.67	57.72	5.95	5.4	0.4	0.00	24.00
106.04.23	1.735	123.4609	125.7656	102.7661	104.3730	0.00	20.6948	-	63.34	57.40	5.95	2.3	0.4	0.00	24.00
107.04.23	1.752	122.7559	125.1240	102.5645	104.2153	0.00	20.1914	-	64.45	58.27	6.17	2.1	0.4	0.01	
23.99.10	1.692	122.2080	124.5537	102.8706	104.5176	0.00	19.3374	-	64.18	58.09	6.09	1.7	0.4	0.00	24.00
108.04.23	1.692	122.2080	124.5537	102.8706	104.5176	0.00	19.3374	-	64.18	58.09	6.09	1.7	0.4	0.00	24.00
109.04.23	1.773	124.0938	126.4326	102.7051	104.3252	0.00	21.3887	-	63.58	57.66	5.92	1.7	0.4	0.00	24.00
110.04.23	1.691	115.3408	117.5283	95.2837	96.7822	0.00	20.0571	-	63.77	57.53	6.24	1.7	0.4	0.00	24.00
111.04.23	1.687	104.7725	106.7471	84.3379	85.6309	0.00	20.4346	-	63.54	56.74	6.80	2.4	0.4	0.00	24.00
112.04.23	1.699	104.5156	106.5303	84.1270	85.4316	0.00	20.3887	-	64.08	57.17	6.91	0.4	0.4	0.00	24.00
113.04.23	1.733	105.6172	107.6133	84.3413	85.6260	0.00	21.2759	-	63.43	56.57	6.86	1.1	0.4	0.00	24.00
114.04.23	1.683	103.5234	105.4961	84.1162	85.4004	0.00	19.4072	-	63.95	56.60	7.34	2.5	0.4	0.00	24.00
115.04.23	1.807	105.2451	107.2949	83.8301	85.1230	0.00	21.4150	-	64.45	56.99	7.46	0.3	0.4	0.00	24.00
116.04.23	1.712	104.7949	106.7813	84.3516	85.6211	0.00	20.4434	-	63.42	56.24	7.18	-0.1	0.4	0.00	24.00
117.04.23	1.756	110.6816	112.7852	90.0791	91.4854	0.00	20.6025	-	64.12	57.30	6.82	5.5	0.4	0.00	24.00
118.04.23	1.687	121.6133	123.8828	102.4209	104.0254	0.00	19.1924	-	63.60	57.46	6.14	6.6	0.4	0.00	24.00
Итого	56.371	3641.8247	3710.9937	2974.4565	3020.9937	0.00	667.3680	0.0000	63.99	57.40	6.59	4.2	0.4		
0.471767	.5310.47														

Показания интеграторов КМ-5

Дата	Время	Q	M1	M2	VI	V1	V2	Tr
18.04.23	24:00	187.764	10879.05	8683.27	0.00	11084.63	8815.43	2591.49
18.03.23	00:00	131.393	7237.22	5708.81	0.00	7373.63	5794.44	1823.96
Итого		56.371	3641.82	2974.46	0.00	3710.99	3020.99	767.53



Отчетный период _____768.00_час. период норм. работы _____767.53_час.

период отключения питания (U) _____0.061_час. период функц. отказа (E) _____0.207_час.

период t1-t2 < min (D) _____0.204_час. период g>t1n (g) _____0.000_час.

период G>max (G) _____0.000_час.

Представитель абонента _____ Представитель теплоснабжающей организации _____



V = 690, 423 кв.м
Qтр.с. = 43,082 Ткач